PRODUCT INFORMATION PACKET



Model No: 182TTGCD6501 Catalog No: U060B

Hazardous Duty® Explosion Proof Motor, 3 & 2 HP, 3 Ph, 60 & 50 Hz, 230/460 & 190/380 V,

3600 & 3000 RPM, 182T Frame, EPFC



Regal and Marathon are trademarks of Regal Rexnord Corporation or one of its affiliated companies.

©2023 Regal Rexnord Corporation, All Rights Reserved. MC017097E






Nameplate Specifications


Phase	3	Output HP	3 & 2 Hp			
Output KW	2.2 & 1.5 kW	Voltage	230/460 & 190/380 V			
Speed	3535 & 2935 rpm	Service Factor	1.0 & 1.0			
Frame	182T	Enclosure	Explosion Proof Fan cooled			
Thermal Protection	Thermostat	Efficiency	86.5 & 84 %			
Ambient Temperature	50 °C	Frequency	60 & 50 Hz			
Current	8/4 & 6.8/3.4 A	Power Factor	82			
Duty	Continuous	Insulation Class	F			
Design Code	В	KVA Code	К			
Drive End Bearing Size	6206	Opp Drive End Bearing Size	6206			
UL	UL Listed And CSA Certified	CSA	Υ			
CE	N	IP Code	54			
Number of Speeds	nber of Speeds 1		DIV 1 EXP PROOF CL I GR CD CL II GR FG T3C			

Technical Specifications

Electrical Type	Squirrel Cage Inverter Rated	Starting Method	Line Or Inverter
Poles	2	Rotation	Reversible
Resistance Main	5.72 Ohms	Mounting	Rigid Base
Motor Orientation	Horizontal	Drive End Bearing	Ball
Opp Drive End Bearing	Ball	Frame Material	Cast Iron
Shaft Type	Т	Shaft Diameter	1.125 in
Assembly/Box Mounting	F1 ONLY	Inverter Load	CONSTANT 10:1
Connection Drawing	EE7308T	Outline Drawing	035660-800

This is an uncontrolled document once printed or downloaded and is subject to change without notice. Date Created:11/29/2023





P.O. BOX 8003 WAUSAU, WI 54401-8003 PH. 715-675-3311 DATA VOLTS: 460												
CERTIFICATION DATA SHEET												
CUSTOMER: ORDER #:						CUSTOMER P.O. #: REFERENCE MODEL #: 182TTGCD6501					!	
CONN. DIA OUTLINE: WINDING:		EE7308T 035660-800 HA31122014	NONE	3				CAT #: CUSTOMER PART #: MOUNTING:		U060B		!
SPEED:						TYPICAL MOTOR PER	RFORM		504205B			
НР	кw	SYNC RPM	FL R	PM		FRAME	ENCLOSURE		TYPE	KVA CODE		DESIGN
3	2.2	3600	353	3535 1		182T	EPFC		TFB	К		В
PH	HZ	VOLTS	AMI			START TYPE	DUTY		INSL	S.F.	AMB	ELEV.
3	60/50 F.L. EFF	230/460#190/380	8/4&6.		1	ACROSS THE LINE 1/2 LD EFF	82.5	CONT GTD EFF	F	1.0	50	3300
	F.L. PF	82.0	3/4 LD EFF	74.5				85.5			ET. TYPE SE IND RUN	
F.L. TORQUE LR. 4.5 LB-FT		LR AMPS @ 32.0			L.R. TORQUE LB-FT 200%		B.D. TORQUE		356%	F.L. RISE (40	° C)	
SOUND PR	RESSURE @	SOUND	ROTOR			MAX. LOAD WK ²		SAFE STALL TIME	STA	ARTS/HOUR	APROX.	MOTOR
70	dBA	79 dBA	0.18	LB-FT ²	5	LB-FT ²	15	SEC.		2	126	LB.
DE BRACKET TYPE		ODE BRACKET TYPE	MOUNT TYPE		*** SUPPLEMENTAL DTOR NTATION SEVERE DUTY		HAZARDOUS LOCATION		DRIP COVER	SCREENS		PAINT
STAN	IDARD	STANDARD	RIGID	HORI	ZONTAL	PREMIUM SEVERE DUTY	DIV 1 EX	P PROOF CL I GR CD CL II GR FG T3C			BLUE - RAL 5003 (EPOXY)	
DE	RINGS ODE	GREASE	SHAFT	TYPE	SPECIAL DE		SPECIAL ODE		SHAFT MATERIAL		FRAME MATERIAL	
6206	6206	POLYREX EM	Т			NONE	NONE		1045 HOT ROLLED (C-204)) CAST IRON	
THERMOSTATS			BRG RTD's NONE		THERMISTORS NONE		CONTROL FALSE		SPACE	HEATERS NA		
R1 (ohms/ph) R2 (ohms/ph)						Xm (ohms/ph)		VIBRATION (in/sec)		FLOAT		
	R1 (ohms/ph) R2 (ohms/ph) X1 (ohms/ph) X2 3.368 1.466 5.799		1.769	121.589		0.080		ODE				
N O T					INVERTER TORQUE: NONE INV. HP SPEED RANGE: NONE							
E					ENCODER: NONE NONE NONE NONE NONE NONE NONE NONE NONE					PPR		
PREPARED BY:						BRAKE: NONE NONE FT-LB: NA						
FORM: 353	FORM: 3531 REV_4 2/27/06					VOLTAGE: NONE HZ: UL: NO LETTER - ALL BRANDS-UL LISTED AND CSA CERTIFIED DIV. 1 XP MOTORS						

CERTIFICATE OF COMPLIANCE

Certificate Number Report Reference 20220221- E12044 E12044-20090313

Issue Date

2022-FEBRUARY-21

Issued to:

REGAL BELOIT AMERICA INC

1946 W COOK RD

FORT WAYNE IN 46818

Tradename: Marathon

This certificate confirms that representative samples of

MOTORS FOR USE IN HAZARDOUS LOCATIONS

Electric motors for use in hazardous locations; Class I, Groups C and D; Class II, Groups F and G; Inclusive of Model Number 182TTGCD6501 (may have prefix and/or

suffix characters).

Have been investigated by UL in accordance with the

Standard(s) indicated on this Certificate.

Standard(s) for Safety:

UL 674 - Electric Motors and Generators for Use in Division

1 Hazardous (Classified) Locations,

CSA C22.2 No. 145, Electric Motors and Generators for

Use in Hazardous (Classified) Locations

Additional Information:

See the UL Online Certifications Directory at

https://iq.ulprospector.com for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Bambles

Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at http://ul.com/aboutul/locations/

